



North Dakota Public Health Laboratory

Final Report

North Dakota Department of Health and Human Services
Laboratory Services
2635 E. Main Avenue
Bismarck, ND 58506-5520

BACTERIOLOGICAL WATER ANALYSIS

Accession#: E26000407

Collector: Kathrin Volochenker

PWSID#: 2800650

Submitter

MERCER CITY OF

PO BOX 118

MERCER, ND 58559

Sample #: E26000407-001

Date/Time Collected: 04/06/2026 09:00
Date/Time Received: 04/06/2026 11:25
Sample Type: Safe Drinking Water

Sampling Reason: Special Purpose
Site: 004

	<u>Result</u>	<u>Date Approved</u>	<u>Time</u>
Total Coliform, Colisure	Negative	04/07/2026	11:57
E. Coli, Colisure	Negative	04/07/2026	11:57

Total Chlorine Residual Result: Not Tested

Comment: Chlorine Residual analysis is performed at the time of collection and is not performed by Laboratory Services.
Precautionary Boil Order - Loss of Pressure

Sample #: E26000407-002

Date/Time Collected: 04/06/2026 08:30
Date/Time Received: 04/06/2026 11:25
Sample Type: Safe Drinking Water

Sampling Reason: Special Purpose
Site: 001

	<u>Result</u>	<u>Date Approved</u>	<u>Time</u>
Total Coliform, Colisure	Negative	04/07/2026	11:57
E. Coli, Colisure	Negative	04/07/2026	11:57

Total Chlorine Residual Result: Not Tested

Comment: Chlorine Residual analysis is performed at the time of collection and is not performed by Laboratory Services.
Precautionary Boil Order - Loss of Pressure

Sample #: E26000407-003

Date/Time Collected: 04/06/2026 09:18
Date/Time Received: 04/06/2026 11:25
Sample Type: Safe Drinking Water

Sampling Reason: Special Purpose
Site: 005

	<u>Result</u>	<u>Date Approved</u>	<u>Time</u>
Total Coliform, Colisure	Negative	04/07/2026	11:57
E. Coli, Colisure	Negative	04/07/2026	11:57

Total Chlorine Residual Result: Not Tested

Comment: Chlorine Residual analysis is performed at the time of collection and is not performed by Laboratory Services.
Precautionary Boil Order - Loss of Pressure

Approved by: _____



Approval date: 04/07/2026